


TA- TENT PERMITS



NO COOKING WITH OPEN FLAME OR GREASE LADEN VAPORS UNDER THE TENTS IS PERMITTED.



10X10 POP UP TENTS

YOU ARE ALLOWED UP TO 4 (FOUR) IN A ROW WITHOUT HAVING TO PULL A PERMIT WITH BFD



THERE MUST BE A 10FT SEPERATION BREAK AFTER 4 TENTS IF NOT PULLING A PERMIT



IF YOU PULL A PERMIT AND GET A FLAME CERTIFICATION FOR THE TENT MATERIAL, YOU CAN PUT THEM IN A ROW WITHOUT SEPARATING.

COULD HAVE 20-30 TENTS IN A ROW



REQUIRES BFD FLAME CERTIFICATION FROM CHEMIST.

-IF USING A TENT VENDOR TO RENT TENTS, MOST ALL OF THE TENT COMPANIES HAVE THIS CERTIFICATION.

-IF USING TENT VENDOR MAKE THEM FILE FOR PERMITS, MOST COMMONLY THEY DO THIS, DON'T LET THEM TELL YOU, THEY DON'T DO THAT

20X20 SIZED TENTS AND ABOVE

BFD TENT WITH ASSEMBLY PERMIT REQUIRED

APPLY ONLINE ON THE BFD PORTAL

1. CHEMIST FLAME CERTIFICATION REQUIRED
(SEPARATE PERMIT)
2. APPLY FOR A TENT WITH ASSEMBLY PERMIT
 - SUBMIT A SITE PLAN OF TENT LOCATION
 - SUBMIT ISD BLDG SHORT FORM
 - IF HAVING OVER **50 OCCUPANTS** SUBMIT AN INTERIOR FLOOR PLAN, SHOWING TABLES, CHAIRS REQUIRED EXITS,ETC
 - IF HAVING OVER **200 OCCUPANTS** MUST SUBMIT WITH AN ARCHITECT OR ENGINEERED PLAN.



WHAT WILL BFD AND ISD INSPECTORS BE LOOKING FOR?

APPROVED PERMITS POSTED INSIDE TENT

TENT IS PROPERLY INSTALLED, EITHER STAKED IN GROUND OR WEIGHED DOWN WITH CONCRETE BLOCKS

LIGHT EXIT SIGNS WHERE REQUIRED BY CODE

TENT IS NOT OVERCROWDED TO APPROVED CAPACITY (MORE TABLES AND CHAIRS THAN ON SUBMITTED PLAN) OR ANY

OTHER ADDED OBSTRUCTIONS, INTERIOR MUST MATCH SUBMITTED PLAN (EXITS, INTERIOR LAYOUTS)

NO FLAMMABLE INTERIOR FINISH MATERIALS HAVE BEEN ADDED TO TENT WITHOUT OBTAINING A BFD CHEM CERT.

PROPER AMOUNT OF REQUIRED EXTINGUISHERS IN THE TENT (ONE 2A:20BC WITHIN EVERY 50 FEET OF TRAVEL DISTANCE)

NO COOKING IS BEING DONE INSIDE TENTS, NO CANDLES IN TENT

CHANGES TO APPROVED PLAN HAVE NOT BEEN MADE (CHANGE EXITS, ADD STAGES,)

