

CITY OF BOSTON INSPECTIONAL SERVICES DEPARTMENT
COMMITTEE ON licenses
HEARING REGARDING FLAMMABLE STORAGE & GARAGES TO BE HELD AT
1010 MASSACHUSETTS AVE, 4TH FLOOR CONFERENCE ROOM
BOSTON, MA 02118
October 30, 2019
10 a.m.

rehearing
370-380 Harrison Ave 180 Vehicles parking garage 3,600 gallons of gas in the tanks of 180 vehciels
South End 10, LLC
Ad - Boston Herald

29 Commonwealth Ave 9 vehicle parking garage 180 gallons of gas in the tanks of vehicles
29 Hexagon LLC
Ad-Boston Herald

25 Porter Street 5 vehicle parking garage 100 Gallons of gas in the tanks of vehicles
160 London LLC
Ad- Boston Herald

New Applications
111 Francis St 8 ambulances in ground level garage- 4 loading vehicles in loading area
Beth Israel Deaconess for the hospital's use 300 gallons of diesel fuel in the tanks of vehicles,
Medical Center 2-300 gallon day tank total 600 gallons on roof
Ad-Boston Herald level of the new structure. 3-15,000 gallon double wall fuel tanks
for a total of 45,000 gallons on the sub basement level of the structure.

47 Sargent St 6 vehicle parking garage - 120 gallons of gas in the tanks of vehicles
Shanti Acquisitions LLC
Ad- Boston Herald

946 Saratoga Street 17 vehicle parking garage 340 gallons of gas in tanks of vehicles
CB Equities Saratoga Street LLC
Ad- Boston Herald

RECEIVED
CITY CLERK'S OFFICE
OCT - 1 P 1:14
BOSTON, MA

Page 2
October 30, 2019
Committee on License hearing

115 Federal Street
MCAF Winthrop LLC
Ad-Boston Herald

500 vehicle parking garage 10,000 gallons of gas in the tanks of vehicles
600 gallons of diesel in day tanks, 3,000 gallons of diesel fuel tanks
50 gallons of miscellaneous items.

99 Summer Street
DIV Sumner Street LLC
Ad- Boston Herald

80 vehicle parking garage 1,600 gallons of gas in the tanks of vehicles

Captain Thomas D. Farrell

Boston Fire Department
Boston Transportation

Brian Ronan

Boston Inspectional Services Department

Brigid Kenny-White
Secretary for the Committee
brigid.kenny@boston.gov

617-961-3270

Next hearing November 20, 2019